

THE PETROLEUM ACT,

(CAP.392)

NOTICE

(*Made under Section 128(3)*)

THE PETROLEUM (COLLINS OIL SERVICE STATION LIMITED) (CONSTRUCTION APPROVAL) NOTICE, 2019

- Citation 1. This Notice may be cited as the Petroleum (Collins Oil Service Station) (Construction Approval) Notice, 2019.
- Commencement 2. This Notice shall take effect from the date of publication in the *Government Gazette*.
- Interpretation 3. Unless the context otherwise requires:
“Applicant” means Collins Oil Service Station Limited of P.O Box 11316 Mwanza;
- Cap. 414 “Authority” means the Energy and Water Utilities Regulatory Authority established under the Energy and Water Utilities Regulatory Authority Act; and
- Cap 392 “Construction Approval” means an approval issued by the Authority pursuant to Section 128(1) the Petroleum Act.
- Granting of a Construction Approval 4. The Applicant is hereby granted a Construction Approval to construct a petroleum products retail outlet at Nyang’homango Village, Usagara Ward, Misungwi District in Mwanza Regionsubject to the following conditions:
- (a) the retail station shall be constructed in

accordance with the Tanzania Bureau of Standards TZS 1115:2009 and TZS 1079:2009;

(b) due care shall be exercised during excavation and installation of underground tanks;

(c) the layout of the retail station shall meet the minimum safety distances in accordance with Tanzania Bureau of Standards TZS 1079:2009;

(d) the underground tanks and associated pipelines shall be well protected from corrosion and the back filling shall be done properly using non-corrosive materials;

(e) the underground storage tanks and pumps together with the connecting pipes and fittings shall be constructed so as to prevent any leakage of fuel;

Cap 340 (f) underground storage tanks and dispensing pumps shall be calibrated by the Weights and Measures Agency established under the Weights and Measures Act;

(g) the forecourt of the retail station shall be paved with impervious materials at the pump island with a drainage provision connected to oil and water separator;

(h) an emergency shut off switch shall be installed in a conspicuous and accessible area;

(i) ensuring that there shall be adequate and clean toilet facilities at all times;

(j) clear and visible safety warning signs shall be installed at the entrance, exit and at the dispensing pumps, including but not limited to "switch off engine", "switch off mobile phone" and "no smoking";

(k) each storage tank shall be fitted with vent pipes with a minimum height of 3.6 metres;

(l) each pump shall be protected with crash barriers with the height of one meter above the ground;

(m) the offloading manhole shall be constructed in accordance with good petroleum industry practices and the offloading receiving pipes should be provided with couplings to prevent spillages during offloading;

(n) the retail station shall be covered with a canopy covering at least the pump island and constructed in accordance with good petroleum industry practices; and

(o) a price board shall be erected in a conspicuous place.

Expiry of a
Constructi
on
Approval

5. The Construction Approval shall automatically expire or cease to have effect if such construction fails to take effect within twenty-four months from the date of issue.

Dodoma
....., 2019

NZINYANGWA E. MCHANY,
Director General